

The 6200, 6300 and 6400 Control systems require the standard generating set mounted circuit breaker to be upgraded to an automatic breaker/contactors.

The circuit breaker is upgraded with motor operator and undervoltage coil for automatic operation.

For circuit breakers up to 100 Amps, the CB3A and CB4A are used.

Circuit breakers 125 Amps and above use MOT4 and MOT3.



## CB4A, CB3A MOT4, MOT3 CB upgrades



## Circuit breakers



**FG Wilson has manufacturing facilities in the following locations:**

**Northern Ireland • Brazil • China • India • USA**

With headquarters in Northern Ireland, FG Wilson operates through a Global Dealer Network. To contact your local Sales Office please visit the FG Wilson website at [www.FGWilson.com](http://www.FGWilson.com)